

Near Net Zero Building Energy Upgrade:
Shell, HVAC, Lighting and Renewable Energy
Proposal Number 11 EB SI4-120

Principal Investigator: Dan Hendrickson
Libre Energy Inc.

PE Consulting GS, Inc. (dba GreenBuild Energy – SDVOSB)
ESTCP Selection Meeting



9/23/2010




Net Zero Energy Project Team

- Libre Energy & GreenBuild Energy - Dan Hendrickson (P/I and Project Manager)
- GreenBuild Energy – Chuck Brands, SDVOSB Principal (G/C and Contract Admin.)
- GreenBuild Energy - Doug Poffinbarger (Energy Engineer)
- Baucentrum Urban Studios - Phil Bona AIA (Architect)
- Design Atlantic - Finith Jernigan AIA, (Onuma & Big BIM/IPD/COBIE Process Consulting)
- Mesa Energy (SoCal) and EMCOR Group (Nationwide TBD) – MEP/HVAC Contracting
- Kelar-Pacific - Mo Mansouri (Building Information Modeling)
- Coolerado - Lee Gillan (HVAC Design Engineer)
- Cyphertech Mechanical - Milt Cyphert (HVAC Installation)
- Regisol – Mike DiPaolo (Ritter Solar CPC45 large Scale Solar System Design)
- Pelican Solar – Morgan Muir (WIOSUN PV-Therm-180/RHC)
- Adroit Solar – SWH/Solar PV Installation
- Energy-Inc – Don Pruss (CHP/ADsorption Chiller™)
- Lavelle Energy – Mike Lavelle – Smart Grid/Demand Response
- Integrated Energy Systems - Monte Lynch - TES



Barrack Environment & Energy Use

- Environmental Conditions
 - ◆ Insolation 400 to 900 watts/m²/hr
 - ◆ Temperature 100 F. to 120 F.
- Electricity use
 - ◆ 486,507 kWh (\$ 35.1 K)/yr
- Peak Demand
 - ◆ 180 kW
 - ◆ \$ 5,778/yr demand charges
- LPG use: 1,123 MMBTU (\$ 15.7 K)/yr.
 - ◆ DHW: 667 MMBTU (\$ 9.2 K)/yr
 - ◆ Space Heat: 471 MMBTU (\$ 6.5 K)/yr
- Energy Cost: \$ 51 K/yr. + \$ 6 K demand = \$ 57 K/yr
- High HVAC System Maintenance



Project Objectives



- Primary Objective: Net Zero Energy Demonstration in a 26,000 SF barrack that houses 68 personnel using a cost effective set of ‘best in class’ building-enhanced energy technologies and “right-time” retrofit processes comprised of:
 - Shell Passive Conservation Measures
 - HVAC and Lighting Efficiency Upgrades
 - Renewable Energy
- Secondary Objective: Demonstrate effectiveness of BIG BIM concepts for managing high-performance “smart energy” retrofits using the Onuma Virtual Real Time Information System (VRIS) platform to:
 - Enable collaborative integration of best-practice BIM, GIS, COBIE, and IPD tools and processes with
 - Building-integrated Energy Retrofits, energy performance monitoring and control
 - Deliver best-value “right-time” retrofits and integrated decision-making support for facilities, asset and energy management

Technical Approach Overview of Project



- Barrack 261: 3 Performance levels, each in a 3 floor, 24 room section

LEVEL DEFINITION

UPGRADES

0 - Current Configuration + Sensors. Baseline - update e-Quest energy model

- ◆ 1 – Moderate Cost:

- Shell: Multi-ceramic reflective coating, R-50 foam roof, 2 Skin Roof; window film
- HVAC: Coolerado, ERV, existing fan coil (motor/control upgrade), EMS

- ◆ 2 - High Performance:

- Shell: Wall R-20 insulation, R-50 foam roof, 2 Skin Roof, Cool Roof Replace Windows
- HVAC: Coolerado, ERV, RHC (radiant heating/cooling), EMS

- ◆ 3 - Best Value - *Upgrade Level 0 with Highest SIR systems in Level 1 & 2 demo..*

- 2012/13

- Barrack 261 Renewable Energy: Solar Water Heating (SWH) and Solar PV

- ◆ SWH: 582 SF of CPV evacuated tube SWH - ___ BTU/yr DHW

- ◆ Solar PV-SWH Hybrid: 32.4 kW PV + __ BTU of SWH @ 90o F.

- ◆ SolarHeart™ 5 kW Mid-temperature Stirling Engine to convert *Waste Heat* to Electricity

Technical Approach Overview of Project (Cont)



- Central Plant 263
 - ◆ 80-RT Adsorption Chiller™
 - ◆ Cooling Tower and District Loop Pump Upgrade
 - ◆ TES (Thermal Energy Storage)
 - ◆ 200 kW CHP micro-turbine (LPG or *SYNGAS* from Waste-to-Energy System)

- 40 ton MSW/day – 1,600 kW Waste-to-Energy-Ft. Irwin Landfill (Option 1)
 - ◆ Lease

- Gray Water Recovery, Purification and Reuse - Cluster 263 (Option 2)

- BIM: Design/Energy Models, Cost Analysis, Project and Maintenance Management

Existing and Proposed Energy Use



Ft. Irwin Barrack 261

Electricity	eQuest Model CERL Slide #6		Proposed Libre Energy		SAVINGS	
	kWh/year		kWh/year			
Passive Measures						
Space Cooling	139000	31.2%	240	0.2%		138760 55.1%
Ventilation/Fans	13400	3.0%	0	0.0%	(3)	13400 5.3%
Pumps, heating/c	66300	14.9%	34000	51.3%		29400 11.7%
Lights	73800	0.8%	36900	19.0%		36900 14.6%
Plug Loads	153500	34.4%	122800	63.3%		30700 12.2%
TOTAL	446000		193940	43.5%		252060
CHP			-259285			
Solar PV			-50308			
			-115653			
Cost	\$ 44,734		\$ (11,600)			
Heating						
	MMBTU/Year		MMBTU/Year			
Space Heating	471		0	0.0%	(1)	471
DHW	667		0	0.0%	(1)	667
Space Cooling	0				(2)	
TOTAL	1,138		0	0.0%		1138
CHP with Syngas						
Cost	\$ 15,586					
Total Cost	\$ 60,319		\$ (11,600)			
Note: (1) Use of SWH (Solar Water Heating) for DHW and SWH + CHP heat for Space Heating will reduce the MMBTU/year requirement to ZERO						
(2) Use of "waste heat" from the DHW and Space Heating SWH systems will provide sufficient 195o F. water to operate a 120 RTcentral Adsorption Chiller..						
(3) An additional 60 tons of cooling/barrack provided with 12 Coolerado M50 air conditioners						

Technology/Methodology Demonstrate



- Barrack Shell Upgrade to conserve
 - ◆ 20% of heating/cooling load
- HVAC
 - ◆ 80% electric energy reduction
 - ◆ 80% demand reduction
 - ◆ 90% LPG reduction - space heating
- Energy Management System - HVAC, Lighting, Plug Loads << O&M \$.
- Renewable Energy:
 - ◆ Solar Water Heating DHW - 85% LPG reduction
 - ◆ Solar PV - 30.3 kW
 - ◆ Waste-to Energy: increase SIR_{20yr} to 1.91 vs. 1.38 for a LNG fueled CHP plant
- Gray water recovery/reuse (25% water saving + pump energy reduction)
- Onuma BIM: Plan, model building + energy, Project & Maintenance Mgmt

Technology/Methodology Maturity

Barrack Shell/HVAC/Lighting/RE Systems



Mature Technology

◆ Building Shell

- EPS Insulation, *Multi-Ceramic Coating*,
- Window Film or Replacement Windows
- *Double-Skin Roof cooled with exhaust air*
- *SolarWall (Option)*

◆ HVAC

- *DOAS - Coolerado Air Conditioning*
- *ERV – RenewAire HE2XINH*
- *CHP + Adsorption Chiller™*

◆ Lighting/Energy Management Systems

◆ Renewable Energy

- *Ritter Solar CPC evacuated tube collectors*
- *WIOSUN Solar PV-Therm-180*
- *SWH Solar-Thermal Stirling Engine*
- *Waste-to-Energy Pyrolizer*
- *ElectroTherm Rankine Cycle Engine*

Engineering/Prototype Development

Night-Sky Radiative Cooling

64 SF Radiant Heating/Cooling Panels

Coolerado Turbine Inlet Cooling

Thermal Energy Storage

SolarHeart™ 5 kW Stirling Engine


17 Innovative Systems - Bolded Italic Print



Technology/Methodology

Building Shell/Passive Heating-Cooling

- Building Shell
 - ◆ Insulation
 - ◆ Reflective Coatings
 - ◆ Fenestration
 - ◆ Vestibules with 2 doors
 - ◆ Corridors are transition zones
- Passive Heating-Cooling
 - ◆ Cool Roof ~ 90% reflectivity
 - ◆ Double-skin roof + building exhaust circulation
 - 800 w/m²/hr reduction in sun loading heat
 - ◆ Night-Sky Radiation Cooling
 - ◆ Evaporative Cooling of Roof Panels
 - ◆ Transpiring SolarWall® on South facade







Passive Heating/Cooling Double-Skin Roof + Circulation of Exhaust Air

Solar Load $900 \text{ W/m}^2/\text{hr} \times 123 \text{ m}^2 \text{ roof}$

Total Solar Load 111 kW/hr

Exhaust air $500 \text{ to } 4,000 \text{ CFM}$

Removes $> 90\%$ of Solar Load



Section Diagram of Double Skinned Wall/Roof

Passive Cooling Night-Sky Radiant Cooling




- Barrack - high thermal mass
- 68 Radiant Heating/Cooling panels used as heat source
 - ◆ ~ 780 F. at room ceiling – 4,080 SF
 - ◆ Reduce CP chilled water use and recirculation at night
- 120 WIOSUN PV-Therm-180 solar panels used as radiators
 - ◆ Night-sky radiation – 1,693 SF
 - ◆ 5.8 – 10.2 W/SF - 17,269 BTU = 1.44 tons
 - ◆ 23.2 – 41.7 W/SF/night in July = 70,598 BTU = 5.88 ton-hours/night
 - ◆ ***Augment with double-skin roof + exhaust + evaporative cooling***
 - 917 BTU/lb. H₂O = 7,336 BTU/gal. = 0.6 tons of cooling/gal. H₂O

Passive Heating/Cooling Transpiring SolarWall®



Barrack 261 South Façade
4518 SF x \$ 27/SF
\$121,986
54 BTU/SF/hr
244,000 BTU/hr
Ft Drum, NY
Ft Carson, CO
Edwards AFB, CA
Ft Huachuca, AZ



Technical Approach HVAC System Architecture



- Barrack 261
 - ◆ Passive Measures
 - ◆ Active Measures
 - DOAS (Dedicated Outside Air System) - Coolerado air conditioner
 - ERV conserve 75% of exhaust air energy
 - Ceiling Mounted Radiant Heating/Cooling (RHC) in barrack room


- Central Plant 263 and District Loop
 - ◆ 80 RT Adsorption Chiller™ - replaces 340 ton electric chiller
 - (TES) Thermal Energy Storage
 - Cooling Tower and Recirculation Pump Upgrade
 - ◆ 200 kW Capstone CHP micro-turbine with Turbine Inlet Cooling

Barrack 261/Central Plant 263 HVAC	Peak Tons	Percent
SolarWall	18.63	14%
Double Skin Roof	18.00	14%
Night-Sky Radiation.	1.44	1%
Coolerado Air Conditioner	52.00	39%
Radiant Heating/Cooling+CHP+Adsorption Chiller™	33.00	25%
ERV (Energy Recovery Ventilator)	8.64	7%
Total HVAC System Capacity	131.71	

Technical Approach Coolerado Air Conditioner



- Elegant Simplicity
- 100 watts/ton of air conditioning
- 52 tons/barrack
- 12% of electric chiller energy
- Solar PV Powered
- $SIR_{10yr} = 1.46$ $SIR_{20yr} = 4.65$



1. Outside Air blown by ECM fan
2. Filter
3. HMX (Heat and Mass Exchanger)
4. Exhaust cools roof & Solar PV panels
5. Product air to Conditioned Space
6. *No Humidity Added to Product Air*







Coolerado Air Conditioner Performance at Ft. Irwin

*Fort Irwin summer conditions:
110o F., 10% Relative Humidity
= 65o F. Coolerado Product Air*

SIR_{10yr} = 1.79

SIR_{20yr} = 1.82



Coolerado air conditioner 100 W/ton performance vs. a 600 W/ton electric chiller

	Coolerado	Electric Chiller	Savings	
Air Flow 5,000 CFM				
Tons	56.53	56.53		43%
Peak kW	7.35	92.75	85.4	92%
kWh/year	18008	155785	137778	
Energy cost/yr	\$1,801	\$15,579		
Water use	127			
Water Cost	\$ 85			
	\$ 1,886	\$15,579	\$13,693	88%
Hours	\$ 4,095	4313		
Hours Condensing	\$ 197	790		
SCE Standard Performance Contract =	\$ 20,667	\$ 8,540	\$ 29,207	\$ 516.70 /ton



Technology/Methodology

Zero Energy Energy HVAC - ERV

- RenewAire Energy Recovery Ventilator
 - ◆ Solar PV Powered
 - ◆ Capacity: 8.64 tons @ 4,500 CFM
 - 36 bathrooms - 1 to 8 air changes/hr. 180 – 1,460 CFM
 - 68 rooms + corridors + laundry/lounge - 1 air change/hr. ~ 3,000 CFM
 - 71% - 80% energy recovery
 - 30 % heating energy savings in winter
 - ◆ Augment ERV blowers with:
 - Bathroom ventilation fans - vary flow from 1 to 8 air changes/hr
 - Control with occupancy/humidity sensors & timers
 - ◆ *RenewAire Solid state core vs. a rotating enthalpy/desiccant wheel*
 - *Low maintenance*
 - *Dehumidify Coolerado inlet air*
- $SIR_{10yr} = 1.20$ $SIR_{20yr} = 1.58$



Technology/Methodology

Low Energy HVAC - Radiant Heat/Cool

- Attach to ceiling as low energy fan coil replacement
 - ◆ ~ 60% of fan coil energy use
 - ◆ *No fan or filter maintenance in rooms*
- Lower District Loop Losses
 - ◆ Hot water – 85o F. vs. 150o F.
 - ◆ Chilled water – 55o F. vs. 40o F
- Reduced
 - ◆ Maintenance and life cycle costs
 - ◆ Installed Cost ~ \$ 2,100/RHC unit - 60 SF area
- 40% reduction in central plant chiller capacity and cost
- *SIR_{20yr} (RHC Panels + Adsorption Chiller™ + TES + CHP)*
 - ◆ SIR_{20yr} LPG = 2.80
 - ◆ SIR_{20yr} SYNGAS = 3.56

Technical Approach

CHP+80-RT Adsorption Chiller™




- CHP waste heat OR Solar Water Heating powered.
- 200 kW_e CHP with 300 kW_{thermal}
- 80 RT Adsorption Chiller
 - ◆ 400 watts
 - ◆ 1.2 MMBTU/80 ton
 - ◆ COP = 0.7
 - ◆ 194o F. water *waste heat* from

CHP LNG or SYNGAS

OR hot water from

- 160 CPC45 solar-thermal collectors
 - ◆ DHW/space heat 1,296 MMBTU/yr
 - ◆ Space cooling 907 MMBTU/yr



Technical Approach

TES (Thermal Energy Storage)



- 80 RT Adsorption Chiller™ and CHP duty cycles are 24/7
 - ◆ Powered with 300 kW_{thermal} C200 CHP micro-turbine ‘waste heat’
- 200% cooling capacity increase achieved by
 - ◆ 80 RT Adsorption Chiller™ augmented with 72,000 gal TES
 - ◆ 240 tons cooling during peak demand timeframe
 - Make and store 9,000 cu ft (72,000 gal.) 40o F. chilled water at night
 - Replace 340 RT electric screw chiller as part of *Cluster 263 energy upgrade*
 - Barrack 261- 36 tons + 36 tons for each non-upgraded barrack + DFAC 48 tons
 - ◆ GRP swimming pool Size
 - 60 ft. x 15 ft. x 10 ft. deep = 9,000 cu. ft. (72,000 gal. ~ 17.3 MMBTU)
 - ◆ Cost = \$ 120 K vs. \$ 307 K for a 160-RT chiller capacity increase
 - ***\$ 187K less than an upgrade to a 240 ton chiller.***



Technical Approach CHP (Combined Heat & Power)



- **Capstone 200 kW micro-turbine (83% efficient)**
 - ◆ 1.8 Million kWh/yr – 205 kW_e continuous - 33% electrical efficiency
 - ◆ 8,533 MMBTU/yr – 974 kBtu continuous - 50% thermal efficiency
 - ◆ \$ 32,400 O&M/yr (\$ 0.018/kWh) + fuel cost
- **CHP electricity and heat allocations/barrack**
 - ◆ 240,000 kWh + 1,219 MMBTU/yr
- **Barrack 261 electricity requirement**
 - ◆ 126,863 kWh/yr after upgrades + Solar PV



Relative NOx Emissions



CARB Natural Gas Emission Standard				
	Units	2003	2007	Reduction
NOx	lb/MWh	0.5	0.07	86%
CO	lb/MWh	6.0	0.10	98%
VOC	lb/MWh	1.0	0.02	98%

Technical Approach

CHP Turbine Inlet Cooling



- Turbine is rated at ISO conditions (59o F. at sea level)
- Micro-turbine performance degrades 22% at 110o F. ambient
- Turbine inlet air temperature cooled to ~ 65o F. with two Coolerado M50 air conditioners.
 - ◆ ~ \$ 36 K installed cost
 - ◆ 65o F. air @ 2,900 CFM
 - ◆ Savings of 257,400 kWh/yr.
 - ◆ SCE Standard Performance Contract could pay up to \$ 38.6 K
 - More than the \$ 36 K Coolerado installation cost.
 - ◆ Savings of ~ \$ 18,584 yr for an estimated 6,500 hours/yr of CHP turbine operation in ambient temperatures above 65o F.
- $SIR_{10yr} =$ $SIR_{20yr} =$



Technical Approach

Lighting & Plug Load Energy Reduction


- LED lighting
- Dimmers
- Occupancy sensors/controls
- Daylight sensors/controls

Technical Approach Energy Management System (EMS)



- Thermostat - Temperature, Coolerado, ERV & RHC Panel Control
- Sense and record in rooms and bathrooms (15 min intervals)

- ◆ Temperature
- ◆ Humidity
- ◆ Coolerado CFM (watts)
- ◆ ERV CFM (watts)
- ◆ RHC Inlet/Outlet Temperature
- ◆ RHC Pump GPM (watts)
- ◆ Room Occupancy
- ◆ Door Open/Closed
- ◆ Bathroom Exhaust: ON/OFF/CFM
- ◆ Lighting Load (watts)
- ◆ Plug Load (watts)



- EMS/BAS Interoperable with Smart Grid

Technical Approach

Solar PV and Water Heating




- 15 Ritter Solar CPC45 evacuated-tube SWH collectors for DHW
 - ◆ 87% of annual DHW demand of 1,020 GPD (15GPD/person)
 - ◆ DHW/space heating capacity – 750 kBTU/day
 - ◆ Low risk - 45,000 residential and 1,003 commercial installations in Europe.
 - ◆ FY 11: 15 CPC45 collectors + 1,000 gal. tank - Barrack 261.
 - ◆ Option: 160 CPC45s Central Plant 263 – Cluster 263 DHW/Space heat/cool
- 120 WIOSUN PV-Therm-180 + 60 PV collectors for PV and SWH
 - ◆ Demonstrate Collector performance in:
 - PV generation - 32.4 kW_e capacity - 71,975 kWh/yr
 - DHW/space heating capacity - 84 kW_{thermal}/287 kBTU
 - Night-sky radiation cooling -
 - ◆ FY 11: 60 PV-Therm-180 Collectors - 1/3 of Barrack 261 (Level 2)
 - ◆ FY 11: 60 Conventional PV Collectors - 1/3 of Barrack 261 (Level 1)
 - ◆ FY 12: 60 PV-Therm-180 Collectors - 1/3 of Barrack 261 (Level 3)



Renewable Energy Solar Water Heating


- DHW 15 Ritter Solar CPC45 collectors

- ◆ SWH 271 MMBTU/yr - 87%
- ◆ DHW Load 313 MMBTU/yr
- ◆ Saves \$ 5,401/yr




■ Solar Contribution 249.530.421 Btu
 ■ Total Energy Consumption 308.833.507 Btu

15 x CPC 45 Star azzurro
 Total Gross Surface Area: 799,20 sq.ft
 Azimuth: 0°
 Incl.: 30°



Daily Maximum Collector Temperature



Renewable Energy

Solar PV – SWH Hybrid



- 120 WIOSUN PV-THERM-180
+ 60 Solar PV Panels
 - ◆ 32.4 kW_e
 - ◆ 71,975 kWh/yr
 - ◆ 84 kW thermal
 - ◆ Solar-thermal removes heat
 - ◆ 100o F. SWH output
 - ◆ PV ~ 25% more efficient than uncooled Solar PV panels




Figure 1: Collector photo of WIOSUN PVT180P Front side



Figure 2: Collector photo of WIOSUN PVT180P Back side




Renewable Energy

SolarHeart™ Stirling Cycle Engine

- Generate ~ 5 kW electricity with SWH system *waste heat*


- ◆ 18 CPC 45 Star Azzuro Collectors
- ◆ Electricity from *waste heat* during
 - 2 week Ft. Irwin block leave period
 - Cooling season

- ◆ Prototype ~ \$ 50 K
- ◆ Production ~ \$ 15 K
 - Cost ~ \$ 6/watt
 - O&M ~ \$ 0.01/kWh



- ◆ Alternate Test Objectives
 - Electricity from
 - CHP *waste heat*
 - Diesel Exhaust

Cumulative Savings in Energy Costs
SolarFlow Payback - Non Financed



Renewable Energy Waste-to-Energy/CHP




- **40 ton/day MSW & sewage sludge:**

- ◆ 40 ton/day pyrolizer at Ft. Irwin landfill.
- ◆ Distribution through Ft. Irwin LPG system.
- ◆ **8 x Central Plant 263 requirement**

- **Syngas for power, heat & cooling:**

- ◆ 1,600 kW distributed CHP.
- ◆ 640 tons Adsorption Chillers™
- ◆ Heat and Cool up to 1.3 million SF



◆ *Syngas SIR_{20yr} = 3.54 vs. 2.80 for LPG*

◆ *Net Savings = \$ 3.0 Million/yr*



Technical Approach

Alternative Demonstration Sites



- USMC Base Camp Pendelton, CA
 - ◆ Net Zero Energy: 8 BEQs/2 Recreation Buildings - 1,600 personnel
 - Waste-to-Energy + 8 Capstone C65 CHP micro-turbines + 600 kW Solar PV
- USMC Base 29 Palms, CA
- USMC Logistics Center; Barstow, CA
- MCAS Miramar; San Diego, CA
- NAVSTA San Diego, CA
- NAS North Island, CA
- MCAS Kaneohe Bay, HI
- NWC China Lake, CA
- Davis Mothan AFB; Tucson, AZ
- MCAS Yuma, AZ
- Camp Billy Machen, NAVSPECWAR Training Center; Niland, CA

Technical Approach Test Program Design



- Incremental Improvement in three 24 room ~ 8,200 SF barrack sections
- Barrack 261 FY 11/12 Upgrade Levels
 - ◆ 0 - Barrack Section AS IS with only sensors added – Baseline for SCE Incentives
 - ◆ 1 - Shell: (R28 multi-ceramic, R50 foam attic), cool roof; Dua- skin roof
HVAC: Coolerado, ERV, retain fan coil, Energy Management System,
Renewable Energy: solar-thermal DHW, Solar PV ~ 10 kW
 - ◆ 2 - Shell (R20 foam wall insulation, R50 foam attic), night-sky cooling, 2 skin roof
HVAC: Coolerado, ERV, RHC, Lighting, P/L, EMS, cool roof, double skin roof
Renewable Energy Solar-thermal DHW, Solar PV-Therm-180 & Solar PV
- Barrack 261 FY 12/13 Upgrade Levels
 - ◆ 3 - Upgrade Level 0 to Level 3 *Best Value* based on FY 11/12 M&V results
- Central Plant 263
 - ◆ FY 11 - Adsorption Chiller™ (use 194o F. water from boiler/SWH) + cooling tower
 - ◆ FY 11 - Capstone C200 CHP micro-turbine + Coolerado turbine inlet cooling
 - ◆ FY 12 - 9,000 cu ft TES (Thermal Energy Storage)
- 40 ton/day Waste-to-Energy - Ft. Irwin landfill

Technical Risk



- HVAC integration into barrack attic (space/access)
- Schedule:
 - ◆ *Require contract award by 12/1/10 to test HVAC in summer 2011*
- Access to Ft. Irwin barrack rooms
 - ◆ Garrison Commander/PWD request work take place only during block leave periods: June 15-30 and Dec 15-30
 - ◆ Request two rooms + bath for HVAC & Lighting system prototyping.
- Design-to-Cost:
 - ◆ SolarHeart™ Stirling Engine and
 - ◆ RHC Panel
- Demonstrating system reliability and maintainability
 - ◆ Onuma BIM for continuous commissioning/maintenance planning
 - ◆ Sensors indicate when systems, pumps, etc. are underperforming
 - Preventative Maintenance Internet and Cellular Telephone Alerts



Expected Benefit

- Transfer technology having the highest Savings-to-Investment Ratios ASAP
 - ◆ Coolerado air conditioner for Turbine Inlet Cooling
 - ◆ Coolerado air conditioner
 - ◆ Waste-to Energy Syngas + CHP + Adsorption Chiller™ + TES + RHC
 - ◆ Ritter Solar CPC45 DHW/Space Heating/Cooling + Adsorption Chiller™ + TES + RHC
 - ◆ Multi-Ceramic & Cool Wall Reflective/Insulation Coatings
 - ◆ SWH/PV, double-skin roof + night-sky radiation cooling
- **40 ton/day W2E \$ 1.5 M/year lease/O&M with Net Savings of \$ 3.0 M/year**
 - Smaller savings with lower MSW burial charges / OR use of Natural Gas vs. LPG
- Environmental Impact - Barrack 261/Central Plant 263
 - GHG 151,196 tons/year reduction
- Environmental Impact - Ft. Irwin Waste-to-Energy
 - 60,800 tons/year GHG reduction
 - Zero landfill at Ft. Irwin – saves 14,600 tons of MSW in landfill/year
- Environmental Impact – Gray-water recovery/reuse
- Water use 2.19 Million gallons/year reduction.
- ***Use of BIM will facilitate transfer of technology and the assessment of environmental benefits to other users.***



ESTPC Review Comments

3. Maintenance

Systems proposed in the Zero Energy Barrack project are low maintenance:

- a. Coolerado air conditioner – *Minimum maintenance, filter change at 6 months.*
- b. ERV (Energy Recovery Ventilator) – *Solid state media – annual cleaning*
- c. RHC Panels – *No moving parts, no filters, fans or controls other than sensors/valves.*
- d. ADSorption Chiller™ - *Nil maintenance on 6 systems installed in CA in 2004 (6 years)*
- e. Cooling Tower - *Dry cooling tower has less maintenance and no water cost*
- f. District Loop Pumps – *Grundfos pumps, minimum maintenance*
- g. CHP - *O&M costs are \$ 0.018/kWh with turnkey contract (continuous commissioning)*
- h. WIOSUN Solar PV-Therm-180 - *Minimum maintenance*
- i. Ritter CPC45 Solar -Thermal – *Minimum maintenance*
- j. SolarHeart™ - *Prototype estimate is \$ 0.01/kWh turnkey contract*
- k. Waste-to-Energy Pyrolizer - *Minimum maintenance, turnkey lease/O&M*
- l. Gray Water Purification and Reuse - *Minimum pump, filter and solar PV maintenance.*



Onuma BIM

- Manage this multi-disciplinary project using Building Information Modeling (BIM) tools, such as the Onuma Planning System that enable integration with best practices to manage these building energy efficiency retrofits and their performance with Onuma Planning Systems BIM, GIS and Virtual Real-Time Information System (VRIS) software tools.

- Tasks facilitated with Onuma BIM
 - ◆ Define,
 - ◆ Design,
 - ◆ Integrated Decision Making
 - ◆ Project Management,
 - ◆ Optimize O&M support of, and
 - ◆ Training in project systems.



Onuma System VRIS: "Digital Maestro" Integrated Management and Decision Support for "Right-Time" Energy Retrofits

Onuma System

The Onuma System interface displays a comprehensive BIM model. Key components include:

- 3D Model:** A perspective view of a multi-story building complex with various colored volumes representing different functional areas.
- 2D Floor Plan:** A detailed architectural drawing showing room layouts, furniture placement, and spatial attributes. A legend on the right lists attributes such as Department, Space Attributes, and Color Selection.
- Furniture List:** A detailed list of furniture items with their respective quantities and specifications, such as 'Room Seating', 'Receptor', and 'Plasma/LED Display'.
- LEED Rating Legend:** A table showing LEED certification levels and their corresponding colors: Gold (Yellow), Silver (Teal), Bronze (Orange), Platinum (Green), and Not Rate (Light Green).
- Building Attributes Table:** A detailed table listing building components and their associated colors and selection options.

Building Attributes	Color	Selection
LEED Rating		
Gold	Yellow	+
Silver	Teal	+
Bronze	Orange	+
Platinum	Green	+
Not Rate	Light Green	+




Real Time "Big BIM" MODEL SERVER




Onuma VRIS/Lavelle VROC Big BIM + Energy “Digital Maestro” Mashup

VRIS Architecture



VRIS Realtime Communications



vROC + Onuma Systems Exported to Google Earth

Onuma System + vROC Exported to Google Earth



Source: <http://www.automatedbuildings.com/news/may10/articles/lavelleenergy/100427104606lavelle.htm>

Onuma VRIS “Digital Maestro”



- Integrated Real-Time Project and Energy Management
- Rapid Project and Energy Planning, Management, and Control
- Multi-Stakeholder Collaboration using “Big BIM” Framework
- Web-based Platform for Virtual Real-Time Rapid Project and Energy Management, Monitoring, and Control
- Interoperable, open-standards-based sensor monitoring and sub-metering for future smart-grid/micro-grid integration.
- “Real-Time” Decision Support of Smart “Right-Time” High Performance Building Energy Retrofits
- Integrate and Leverage Existing Software and Processes
- Secure, Interoperable Web-Based BIM/GIS Platform Linking Facilities Condition to Mission-Readiness
- COBie-Certified for Building Information Exchange (see note)
- Smart Grid Interactive
- Output formatted for DD1391 entries.



EMS/Smart-Grid/Demand Response

Reliability-based: “emergency” and “capacity” programs

- ◆ Most common: *“interruptible/curtailable” rates*
- ◆ Oldest variety: also called *“active load management”*
- ◆ Also includes *direct load control*
- ◆ Program calls usu. *require mandatory response ?*

Price-based: “economic” programs

- ◆ Participation usually voluntary
- ◆ *Day-of and day-ahead options*
- ◆ Demand bidding programs
- ◆ Tariff-based: *real-time, time-of-use, and “critical peak” pricing*



Added CHP to meet Demand Response

- 100% overcapacity in Waste-to-Energy + CHP micro-turbine
- 3,200 kW vs. 1,600 kW distributed micro-turbine capacity
 - ◆ 3,200 kW **100%** 6 hour peak demand - **11.6% of 27,504 kW July peak**
 - ◆ 1,200 kW **38%** during 12 hour semi-peak
 - ◆ 800 kW **50%** during 6 hour off-peak
- Sufficient *SYNGAS* generated to meet demand at 1,600 kW
 - Compress and store excess SYNGAS at semi-peak & off-peak
- Syngas compression at night creates heat
 - DHW and space heating
- Syngas expansion at peak demand = energy + cooling
 - Drive air motor and/or reduce CHP Turbine compression work
 - Augment air conditioning
 - Augment turbine inlet cooling



UESC Example



- USMC Logistics Ctr. Barstow, CA
- 1.5 MW wind turbine
- \$4.6 million financed by Southern California Edison
 - ◆ \$6.1M total, minus \$1.5M SCE rebate
- \$515 K annual savings
- 15 year term
- Similar in scope to Ft Irwin
 - ◆ 1.6 MW Waste-to-Energy
 - ◆ 1.6 MW CHP microturbines
 - ◆ 640 ton Adsorption Chillers™
 - ◆ TES